



Portable Appliance Testing Report

ABC Company Ltd

Test Period Commencing

01-Nov-2023

Order No

366545

Company Contact Name

Alan Smith

Certificate of Electrical Appliance Testing

Client Details

ABC Company Ltd
1 Smith Street
Simpson Trade Estate
Big Town
A12 3BC

Certification

This Certificate should be presented alongside the Record of Testing and proves the testing of equipment in that report to the standard within BS EN 50699. The Risk Assessment by the Duty Holder should also be considered.

Date Tested:

01/11/2023

Signature



Certificate Number RA-004920

Carried out by

DRA PAT Testing Ltd
27 Coquet Gardens
Wallsend
Tyne and Wear
NE28 6AG
Phone: 01916661009
Mobile: 07897240878
Email: info@draelectricals.co.uk
Web: draelectricals.co.uk



PAT Report Passes For all Sites and Locations

CLIENT DETAILS

Company Name: ABC Company Ltd

Address: 1 Smith Street
Simpson Trade Estate
Big Town
A12 3BC



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING

Company Name: DRA PAT Testing Ltd

Address: 27 Coquet Gardens
Wallsend
Tyne and Wear
NE28 6AG

Telephone: 01916661009

Mobile: 07897240878

Email: info@draelectricals.co.uk

Web: draelectricals.co.uk

Cert Number: RA-004920

Order Number: 366545

File Name: ABC 111.PAT

Signature:

Electrical Equipment Certificate Report

PAT TESTER DETAILS

Serial Number	Make and Model	Certificate Number	Calibration Due Date
44G-0452	Seaward - Apollo 600	btm11770	12/09/2024
20E-0267	Seaward - Apollo 600	btm11771	21/09/2024
22J-0865	Seaward - Apollo 600	btm11432	19/07/2024
22K-0038	Seaward - Apollo 600	btm11431	19/07/2024

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
ABC COMPANY - ASSISTANT MANAGER								
1028874	6 GANG EXTENSION LEAD	01/11/23	ROB	P	P	P 0.12	P 19.99	PASS
1028875	PC	01/11/23	ROB	P	S	P 0.07	P 19.99	PASS
1028876	MONITOR	01/11/23	ROB	P	S	P 0.07	P 19.99	PASS
1028877	IEC LEAD	01/11/23	ROB	P	P	P 0.11	P 19.99	PASS
1028878	IEC LEAD	01/11/23	ROB	P	P	P 0.13	P 19.99	PASS
Total Appliances >								5

ABC COMPANY - ASSISTANT MANAGER 2

1029896	MONITOR	01/11/23	JANE	P	S	P 0.05	P 19.99	PASS
1029897	MONITOR	01/11/23	JANE	P	S	P 0.05	P 19.99	PASS
1029898	4 GANG EXTENSION LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029899	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029900	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
--------------	-----------------------	-----------	----------	--------	----------	-------------------------	--------------------	----------------

Total Appliances > **5**

ABC COMPANY - BOILER HOUSE

1027700	PILLAR DRILL	02/11/23	KYLE	P	S	P 0.11	P 19.99	PASS
1027701	WORK LIGHT	02/11/23	KYLE	P	S	P 0.11	P 19.99	PASS
1027702	FRETSAW	02/11/23	KYLE	P	S	P 0.09	P 19.99	PASS
1027704	CHOP SAW	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027705	EXTENSION LEAD	02/11/23	KYLE	P	S	S	S	PASS

Total Appliances > **5**

ABC COMPANY - BUSINESS MANAGER

1029901	MONITOR	01/11/23	JANE	P	S	P 0.07	P 19.99	PASS
1029902	MONITOR	01/11/23	JANE	P	S	P 0.05	P 19.99	PASS
1029903	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029904	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS

Total Appliances > **4**

ABC COMPANY - CANTEEN

1027553	AC ADAPTER	01/11/23	KYLE	P	S	S	S	PASS
1027554	FIG 8 LEAD	01/11/23	KYLE	P	S	S	S	PASS
1027555	LAPTOP CHARGER	01/11/23	KYLE	P	S	S	S	PASS
1027706	SPLITTER UNIT	02/11/23	KYLE	P	S	S	S	PASS
1027707	WIRELESS RECEIVER	02/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
1027708	AUDIO MIXER	02/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
1027709	AMPLIFIER	02/11/23	KYLE	P	S	P 0.09	P 19.99	PASS
1027710	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027711	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027712	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027713	IEC LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027714	IEC LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027715	POWER SUPPLY	02/11/23	KYLE	P	S	S	S	PASS
1027716	CLASS 1 LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027717	EXTENSION LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027718	IEC LEAD	02/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027719	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027720	APPLE TV	02/11/23	KYLE	P	S	S	S	PASS
1027721	AMPLIFIER	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027722	AMPLIFIER	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027723	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027724	FRIDGE	02/11/23	KYLE	P	S	P 0.08	P 19.99	PASS
1027725	CHEST FREEZER	02/11/23	KYLE	P	S	P 0.16	P 19.99	PASS
1027726	4 GANG EXTENSION LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027727	MONITOR	02/11/23	KYLE	P	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1027728	IEC LEAD	02/11/23	KYLE	P	P	P 0.14	P 19.99	PASS
1027729	POWER SUPPLY	02/11/23	KYLE	P	S	S	S	PASS
1027730	FLOOR BUFFER	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027731	FLOOR BUFFER	02/11/23	KYLE	P	S	S	P 19.99	PASS
Total Appliances >								29

ABC COMPANY - CLEANERS

1029887	VACUUM CLEANER	01/11/23	JANE	P	S	S	P 19.99	PASS
Total Appliances >								1

ABC COMPANY - ENTRANCE

1029884	PHOTOCOPIER	01/11/23	JANE	P	S	P 0.08	P 19.99	PASS
1029885	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029886	TELEVISION WALL MOUNTED	01/11/23	JANE	P	S	S	S	PASS
Total Appliances >								3

ABC COMPANY - ENTRANCE AREA

1027556	TELEVISION	01/11/23	KYLE	P	S	S	P 19.99	PASS
Total Appliances >								1

ABC COMPANY - EVENTS SPACE

1027683	SPLITTER UNIT	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027684	WIRELESS RECEIVER	02/11/23	KYLE	P	S	P 0.08	P 19.99	PASS
1027685	AUDIO MIXER	02/11/23	KYLE	P	S	P 0.20	P 19.99	PASS
1027686	AMPLIFIER	02/11/23	KYLE	P	S	P 0.12	P 19.99	PASS
1027687	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027688	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027689	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027690	IEC LEAD	02/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027691	IEC LEAD	02/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027692	CLASS 1 LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027693	CLASS 1 LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027694	POWER SUPPLY	02/11/23	KYLE	P	S	S	S	PASS
1027695	POWER SUPPLY	02/11/23	KYLE	P	S	S	S	PASS
1027696	EXTENSION LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027697	IEC LEAD	02/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027698	SPEAKER	02/11/23	KYLE	P	S	P 0.09	P 19.99	PASS
1027699	VACUUM CLEANER	02/11/23	KYLE	P	S	S	S	PASS
Total Appliances >								17

ABC COMPANY - FACILITIES MANAGER

1028860	USB PLUG	01/11/23	ROB	P	S	S	S	PASS
1028861	USB PLUG	01/11/23	ROB	P	S	S	S	PASS
1028862	FAN HEATER	01/11/23	ROB	P	S	S	S	PASS
1028863	AC ADAPTER	01/11/23	ROB	P	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1028864	FAN	01/11/23	ROB	P	S	S	S	PASS
1028865	AC ADAPTER	01/11/23	ROB	P	S	S	S	PASS
1028866	PC	01/11/23	ROB	P	S	P 0.04	P 19.99	PASS
1028867	MONITOR	01/11/23	ROB	P	S	P 0.07	P 19.99	PASS
1028868	MONITOR	01/11/23	ROB	P	S	P 0.08	P 19.99	PASS
1028869	IEC LEAD	01/11/23	ROB	P	P	P 0.14	P 19.99	PASS
1028870	IEC LEAD	01/11/23	ROB	P	P	P 0.12	P 19.99	PASS
1028871	IEC LEAD	01/11/23	ROB	P	P	P 0.12	P 19.99	PASS
1028872	IEC LEAD	01/11/23	ROB	P	P	P 0.12	P 19.99	PASS
1028873	IEC LEAD	01/11/23	ROB	P	P	P 0.11	P 19.99	PASS

Total Appliances > **14**

ABC COMPANY - FIRST AID

1027642	FRIDGE FREEZER	02/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
---------	----------------	----------	------	---	---	--------	---------	------

Total Appliances > **1**

ABC COMPANY - HALLWAY

1027732	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027733	HOT PLATE	02/11/23	KYLE	P	S	P 0.11	P 19.99	PASS
1027734	MICROSCOPE	02/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
1027735	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027736	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027737	USB PLUG	02/11/23	KYLE	P	S	S	S	PASS

Total Appliances > **6**

ABC COMPANY - KITCHEN

1027412	TUMBLE DRYER	01/11/23	KYLE	P	S	P 0.09	P 19.99	PASS
1027413	FRIDGE	01/11/23	KYLE	P	S	P 0.08	P 19.99	PASS
1027414	FRIDGE FREEZER	01/11/23	KYLE	P	S	P 0.09	P 19.99	PASS
1027415	KETTLE	01/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
1027416	KETTLE BASE	01/11/23	KYLE	P	S	P 0.06	P 19.99	PASS
1027417	MICROWAVE OVEN	01/11/23	KYLE	P	S	P 0.09	P 19.99	PASS
1027418	DISHWASHER	01/11/23	KYLE	P	S	P 0.08	P 19.99	PASS
1027419	WASHING MACHINE	01/11/23	KYLE	P	S	P 0.07	P 19.99	PASS
1027420	AC ADAPTER BATTERY CHARGER	01/11/23	KYLE	P	S	S	S	PASS
1027446	FAN	01/11/23	KYLE	P	S	S	S	PASS
1027447	INDUCTION HOB	01/11/23	KYLE	P	S	P 0.16	P 19.99	PASS
1027448	MIXING UNIT	01/11/23	KYLE	P	S	P 0.16	P 19.99	PASS
1027449	BENCH FRIDGE	01/11/23	KYLE	P	S	P 0.11	P 19.99	PASS
1027450	BENCH FRIDGE	01/11/23	KYLE	P	S	P 0.07	P 19.99	PASS
1027547	STICK BLENDER	01/11/23	KYLE	P	S	S	P 19.99	PASS
1027548	EXTRACTOR UNIT	01/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
1027549	EXTRACTOR UNIT	01/11/23	KYLE	P	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1027550	BENCH FRIDGE	01/11/23	KYLE	P	S	P 0.11	P 19.99	PASS
1027551	KETTLE BASE	01/11/23	KYLE	P	S	P 0.06	P 19.99	PASS
1027552	KETTLE	01/11/23	KYLE	P	S	P 0.11	P 19.99	PASS
1029913	FRIDGE	01/11/23	JANE	P	S	P 0.07	P 19.99	PASS
1029914	FRIDGE	01/11/23	JANE	P	S	P 0.08	P 19.99	PASS
1029915	FREEZER	01/11/23	JANE	P	S	P 0.07	P 19.99	PASS
1029916	FREEZER	01/11/23	JANE	P	S	P 0.07	P 19.99	PASS
1029917	MEAT SLICER	01/11/23	JANE	P	S	P 0.07	P 19.99	PASS
1029918	LIGHT	01/11/23	JANE	P	S	P 0.09	P 19.99	PASS
1029919	MIXER	01/11/23	JANE	P	S	P 0.05	P 19.99	PASS
1029920	AC ADAPTER SPEAKER	01/11/23	JANE	P	S	S	S	PASS
1029921	BLENDER	01/11/23	JANE	P	S	S	P 19.99	PASS
1029922	TOASTER	01/11/23	JANE	P	S	P 0.07	P 19.99	PASS
1029923	WASHING MACHINE	01/11/23	JANE	P	S	P 0.10	P 19.99	PASS
1029924	KETTLE	01/11/23	JANE	P	S	P 0.07	P 19.99	PASS
1029925	KETTLE BASE	01/11/23	JANE	P	S	P 0.07	P 19.99	PASS

Total Appliances > **33**

ABC COMPANY - MANAGING DIRECTOR

1029888	MONITOR	01/11/23	JANE	P	S	P 0.05	P 19.99	PASS
1029889	MONITOR	01/11/23	JANE	P	S	P 0.06	P 19.99	PASS
1029890	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029891	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029892	4 GANG EXTENSION LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029893	OIL HEATER	01/11/23	JANE	P	S	P 0.07	P 19.99	PASS
1029894	USB PLUG	01/11/23	JANE	P	S	S	S	PASS
1029895	TELEVISION WALL MOUNTED	01/11/23	JANE	P	S	S	S	PASS

Total Appliances > **8**

ABC COMPANY - MEETING ROOM

1027557	IEC LEAD	01/11/23	KYLE	P	P	P 0.13	P 19.99	PASS
1027558	LAPTOP CHARGER	01/11/23	KYLE	P	S	S	S	PASS
1027559	TELEVISION	01/11/23	KYLE	P	S	S	P 19.99	PASS
1027560	USB PLUG	01/11/23	KYLE	P	S	S	S	PASS

Total Appliances > **4**

ABC COMPANY - NEW KITCHEN

1027561	BATTERY CHARGER	01/11/23	KYLE	P	S	S	P 19.99	PASS
1027562	TOASTER	01/11/23	KYLE	P	S	P 0.12	P 19.99	PASS
1027563	TOASTER	01/11/23	KYLE	P	S	P 0.12	P 19.99	PASS
1027564	FRIDGE FREEZER	01/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
1027565	MICROWAVE OVEN	01/11/23	KYLE	P	S	P 0.06	P 19.99	PASS
1027566	SMART BOARD	01/11/23	KYLE	P	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1027567	WATER BOILER	01/11/23	KYLE	P	S	P 0.07	P 19.99	PASS
1027568	SHREDDER	01/11/23	KYLE	P	S	P 0.09	P 19.99	PASS
1027569	IEC LEAD	01/11/23	KYLE	P	P	P 0.34	P 19.99	PASS

Total Appliances > **9**

ABC COMPANY - OFFICE EIGHT

1027746	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027747	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027748	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027749	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027750	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027751	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027752	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027753	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027754	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027755	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027756	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027757	IEC LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027758	IEC LEAD	02/11/23	KYLE	P	P	P 0.12	P 19.99	PASS
1027759	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027760	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027761	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027762	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027763	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027764	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027765	IEC LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027766	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027767	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027768	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027769	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027770	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027771	IEC LEAD	02/11/23	KYLE	P	P	P 0.14	P 19.99	PASS
1027772	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027773	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027774	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027775	IEC LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027776	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027777	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027778	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027779	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Earth Continuity (Ohms)			Insulation (MOhms)	Overall Status
				Visual	Polarity	Earth Continuity		
1027780	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027781	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027782	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027783	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027784	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027785	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027786	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027787	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027788	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027789	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027790	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027791	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027792	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027793	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027794	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027795	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027796	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027797	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027798	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027799	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027800	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027801	4 GANG EXTENSION LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027802	4 GANG EXTENSION LEAD	02/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027803	4 GANG EXTENSION LEAD	02/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027804	4 GANG EXTENSION LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027805	4 GANG EXTENSION LEAD	02/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027806	4 GANG EXTENSION LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027807	4 GANG EXTENSION LEAD	02/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027808	USB PLUG	02/11/23	KYLE	P	S	S	S	PASS
1028036	FIG 8 LEAD	02/11/23	CHELSEA	P	S	S	S	PASS
1028037	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028038	FIG 8 LEAD	02/11/23	CHELSEA	P	S	S	S	PASS
1028039	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028040	FIG 8 LEAD	02/11/23	CHELSEA	P	S	S	S	PASS
1028041	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028042	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.31	P 19.99	PASS
1028043	6 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.08	P 19.99	PASS
1028044	6 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.10	P 19.99	PASS
1028045	MONITOR	02/11/23	CHELSEA	P	S	P 0.04	P 19.99	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1028046	MONITOR	02/11/23	CHELSEA	P	S	P 0.04	P 19.99	PASS
1028047	MONITOR	02/11/23	CHELSEA	P	S	P 0.04	P 19.99	PASS
1028048	MONITOR	02/11/23	CHELSEA	P	S	P 0.04	P 19.99	PASS
1028049	MONITOR	02/11/23	CHELSEA	P	S	P 0.04	P 19.99	PASS
1028050	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028051	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028052	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028053	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028054	PC	02/11/23	CHELSEA	P	S	P 0.03	P 19.99	PASS
1028055	SMART BOARD7	02/11/23	CHELSEA	P	S	P 0.02	P 19.99	PASS
1028056	HYDROLIC STAND	02/11/23	CHELSEA	P	S	P 0.05	P 19.99	PASS
1028057	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028058	USB PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028059	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028060	FIG 8 LEAD	02/11/23	CHELSEA	P	S	S	S	PASS
1028061	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028062	IEC LEAD7	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028063	SMART BOARD	02/11/23	CHELSEA	P	S	P 0.16	P 19.99	PASS
1028064	HYDROLIC STAND	02/11/23	CHELSEA	P	S	P 0.02	P 19.99	PASS
1028065	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.16	P 19.99	PASS
1028066	FIG 8 LEAD	02/11/23	CHELSEA	P	S	S	S	PASS
1028067	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028068	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028069	SMART BOARD	02/11/23	CHELSEA	P	S	P 0.08	P 19.99	PASS
1028070	HYDROLIC STAND	02/11/23	CHELSEA	P	S	P 0.09	P 19.99	PASS
1028071	AC ADAPTER	02/11/23	CHELSEA	P	S	S	S	PASS
1028230	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028231	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028232	LAPTOP CHARGER	02/11/23	CHELSEA	P	S	S	S	PASS
1028233	LAPTOP CHARGER	02/11/23	CHELSEA	P	S	S	S	PASS
1028234	3 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.06	P 19.99	PASS
1028235	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.06	P 19.99	PASS
1028236	3 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS

Total Appliances > **106**

ABC COMPANY - OFFICE FIVE

1027589	AC ADAPTER PENCIL SHARPENER	02/11/23	KYLE	P	S	S	S	PASS
1027590	AC ADAPTER BATTERY CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027591	FIG 8 LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027592	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1027593	SMART BOARD	02/11/23	KYLE	P	S	P 0.09	P 19.99	PASS
1027594	HYDRAULIC STAND	02/11/23	KYLE	P	S	P 0.06	P 19.99	PASS
1027595	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027596	IEC LEAD	02/11/23	KYLE	P	P	P 0.07	P 19.99	PASS
1027597	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027598	SMART BOARD	02/11/23	KYLE	P	S	P 0.07	P 19.99	PASS
1027599	HYDRAULIC STAND	02/11/23	KYLE	P	S	P 0.08	P 19.99	PASS
1027600	IEC LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027601	MONITOR	02/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
1027602	MONITOR	02/11/23	KYLE	P	S	P 0.12	P 19.99	PASS
1027603	SMART BOARD	02/11/23	KYLE	P	S	P 0.07	P 19.99	PASS
1027604	HYDRAULIC STAND	02/11/23	KYLE	P	S	P 0.08	P 19.99	PASS
1027605	IEC LEAD	02/11/23	KYLE	P	P	P 0.07	P 19.99	PASS
1027606	IEC LEAD	02/11/23	KYLE	P	P	P 0.07	P 19.99	PASS
1027607	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS

Total Appliances > **19**

ABC COMPANY - OFFICE FOUR

1027570	MONITOR	02/11/23	KYLE	P	S	P 0.12	P 19.99	PASS
1027571	MONITOR	02/11/23	KYLE	P	S	P 0.11	P 19.99	PASS
1027572	SMART BOARD	02/11/23	KYLE	P	S	P 0.12	P 19.99	PASS
1027573	HYDRAULIC STAND	02/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
1027574	IEC LEAD	02/11/23	KYLE	P	P	P 0.12	P 19.99	PASS
1027575	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027576	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027577	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027578	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027579	SMART BOARD	02/11/23	KYLE	P	S	P 0.12	P 19.99	PASS
1027580	HYDRAULIC STAND	02/11/23	KYLE	P	S	P 0.15	P 19.99	PASS
1027581	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027582	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS
1027583	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027584	USB PLUG	02/11/23	KYLE	P	S	S	S	PASS
1027585	SMART BOARD	02/11/23	KYLE	P	S	P 0.09	P 19.99	PASS
1027586	HYDRAULIC STAND	02/11/23	KYLE	P	S	P 0.13	P 19.99	PASS
1027587	IEC LEAD	02/11/23	KYLE	P	P	P 0.16	P 19.99	PASS
1027588	AC ADAPTER BATTERY CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027643	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027644	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027645	IEC LEAD	02/11/23	KYLE	P	P	P 0.14	P 19.99	PASS

Total Appliances > **22**

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
ABC COMPANY - OFFICE NINE								
1027996	MONITOR	02/11/23	CHELSEA	P	S	P 0.10	P 19.99	PASS
1027997	MONITOR	02/11/23	CHELSEA	P	S	P 0.08	P 19.99	PASS
1027998	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.06	P 19.99	PASS
1027999	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.06	P 19.99	PASS
1028000	FIG 8 LEAD	02/11/23	CHELSEA	P	S	S	S	PASS
1028001	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028002	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.09	P 19.99	PASS
1028003	SMART BOARD	02/11/23	CHELSEA	P	S	P 0.07	P 19.99	PASS
1028004	HYDROLIC STAND	02/11/23	CHELSEA	P	S	P 0.03	P 19.99	PASS
1028005	AC ADAPTER	02/11/23	CHELSEA	P	S	S	S	PASS
1028006	FIG 8 LEAD	02/11/23	CHELSEA	P	S	S	S	PASS
1028007	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028008	HYDROLIC STAND	02/11/23	CHELSEA	P	S	P 0.09	P 19.99	PASS
1028009	SMART BOARD	02/11/23	CHELSEA	P	S	P 0.05	P 19.99	PASS
1028010	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.06	P 19.99	PASS
1028080	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028081	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028082	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028083	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028084	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028085	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028086	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028087	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028088	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028089	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028090	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028091	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028092	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028093	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028094	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028095	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028096	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028097	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028098	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028099	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028100	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028101	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028102	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1028103	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028104	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028105	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028106	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028107	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028108	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028109	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028110	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028111	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028112	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028113	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028114	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028115	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028116	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028117	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028118	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028119	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028120	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028121	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028122	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028123	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028124	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028125	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028126	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028127	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028128	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028129	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028130	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028131	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028132	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028133	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028134	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028135	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028136	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028137	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028138	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028139	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028140	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028141	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1028142	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028143	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028144	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028145	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028146	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028147	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028148	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028149	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028150	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028151	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS
1028152	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028153	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028154	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028155	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS
1028156	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS

Total Appliances > **92**

ABC COMPANY - OFFICE ONE

1029905	PENCIL SHARPNER	01/11/23	JANE	P	S	P 0.06	P 19.99	PASS
1029906	LAMINATOR	01/11/23	JANE	P	S	P 0.07	P 19.99	PASS
1029907	LAMINATOR	01/11/23	JANE	P	S	P 0.08	P 19.99	PASS
1029908	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029909	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029910	AC ADAPTER	01/11/23	JANE	P	S	S	S	PASS
1029911	2 GANG EXTENSION LEAD	01/11/23	JANE	P	S	S	S	PASS
1029912	4 GANG EXTENSION LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS

Total Appliances > **8**

ABC COMPANY - OFFICE SEVEN

1027745	IEC LEAD	02/11/23	KYLE	P	P	P 0.07	P 19.99	PASS
1028011	MONITOR	02/11/23	CHELSEA	P	S	P 0.04	P 19.99	PASS
1028012	MONITOR	02/11/23	CHELSEA	P	S	P 0.05	P 19.99	PASS
1028013	MONITOR	02/11/23	CHELSEA	P	S	P 0.04	P 19.99	PASS
1028014	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS
1028015	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.07	P 19.99	PASS
1028016	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.07	P 19.99	PASS
1028017	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.08	P 19.99	PASS
1028018	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.07	P 19.99	PASS
1028019	SMART BOARD	02/11/23	CHELSEA	P	S	P 0.04	P 19.99	PASS
1028020	HYDROLIC STAND	02/11/23	CHELSEA	P	S	P 0.04	P 19.99	PASS
1028021	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.13	P 19.99	PASS
1028022	AC ADAPTER	02/11/23	CHELSEA	P	S	S	S	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Earth Continuity (Ohms)			Insulation (MOhms)	Overall Status
				Visual	Polarity	Earth Continuity (Ohms)		
1028023	FIG 8 LEAD	02/11/23	CHELSEA	P	S	S	S	PASS
1028024	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028025	APPLE PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028026	SMART BOARD	02/11/23	CHELSEA	P	S	P 0.08	P 19.99	PASS
1028027	HYDROLIC STAND	02/11/23	CHELSEA	P	S	P 0.07	P 19.99	PASS
1028028	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS
1028029	AC ADAPTER	02/11/23	CHELSEA	P	S	S	S	PASS
1028030	USB PLUG	02/11/23	CHELSEA	P	S	S	S	PASS
1028031	FIG 8 LEAD	02/11/23	CHELSEA	P	S	S	S	PASS
1028032	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028033	SMART BOARD	02/11/23	CHELSEA	P	S	P 0.09	P 19.99	PASS
1028034	HYDROLIC STAND	02/11/23	CHELSEA	P	S	P 0.05	P 19.99	PASS
1028035	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028072	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028073	PHOTOCOPIER8	02/11/23	CHELSEA	P	S	P 0.02	P 19.99	PASS
1028074	PHOTOCOPIER	02/11/23	CHELSEA	P	S	P 0.05	P 19.99	PASS
1028075	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028157	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028158	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028159	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028160	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028161	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028162	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028163	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028164	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028165	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028166	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028167	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028168	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028169	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028170	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028171	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028172	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028173	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028174	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS
1028175	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028176	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028177	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS
1028178	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1028179	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028180	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS
1028181	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028182	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028183	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028184	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028185	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028186	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028187	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028188	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028189	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028190	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028191	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028192	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028193	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028194	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028195	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028196	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028197	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028198	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028199	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028200	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028201	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028202	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028203	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028204	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028205	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028206	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028207	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028208	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028209	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS
1028210	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028211	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028212	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028213	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS
1028214	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS
1028215	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028216	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.05	P 19.99	PASS
1028217	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1028218	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028219	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028220	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028221	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028222	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028223	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028224	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028225	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028226	POWER SUPPLY	02/11/23	CHELSEA	P	S	S	S	PASS
1028227	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028228	4 GANG EXTENSION LEAD	02/11/23	CHELSEA	P	P	P 0.04	P 19.99	PASS
1028229	IEC LEAD	02/11/23	CHELSEA	P	P	P 0.14	P 19.99	PASS

Total Appliances > **103**

ABC COMPANY - OFFICE SIX

1027608	AC ADAPTER BATTERY CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027609	USB PLUG	02/11/23	KYLE	P	S	S	S	PASS
1027610	USB PLUG	02/11/23	KYLE	P	S	S	S	PASS
1027611	SPEAKER	02/11/23	KYLE	P	S	S	S	PASS
1027612	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027613	SMART BOARD	02/11/23	KYLE	P	S	P 0.11	P 19.99	PASS
1027614	HYDRAULIC STAND	02/11/23	KYLE	P	S	P 0.13	P 19.99	PASS
1027615	IEC LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027616	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027617	4 GANG EXTENSION LEAD	02/11/23	KYLE	P	P	P 0.24	P 19.99	PASS
1027618	AC ADAPTER AIR FRESHENER	02/11/23	KYLE	P	S	S	S	PASS
1027619	AC ADAPTER PENCIL SHARPENER	02/11/23	KYLE	P	S	S	S	PASS
1027620	FIG 8 LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027621	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027622	USB PLUG	02/11/23	KYLE	P	S	S	S	PASS
1027623	SMART BOARD	02/11/23	KYLE	P	S	P 0.07	P 19.99	PASS
1027624	HYDRAULIC STAND	02/11/23	KYLE	P	S	P 0.06	P 19.99	PASS
1027625	IEC LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027626	AC ADAPTER AIR FRESHENER	02/11/23	KYLE	P	S	S	S	PASS
1027627	AC ADAPTER PENCIL SHARPENER	02/11/23	KYLE	P	S	S	S	PASS
1027628	AC ADAPTER PENCIL SHARPENER	02/11/23	KYLE	P	S	S	S	PASS
1027629	GLUE GUN	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027630	MONITOR	02/11/23	KYLE	P	S	P 0.11	P 19.99	PASS
1027631	MONITOR	02/11/23	KYLE	P	S	P 0.12	P 19.99	PASS
1027632	SMART BOARD	02/11/23	KYLE	P	S	P 0.15	P 19.99	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1027633	HYDRAULIC STAND	02/11/23	KYLE	P	S	P 0.37	P 19.99	PASS
1027634	IEC LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027635	LAPTOP CHARGER	02/11/23	KYLE	P	S	S	S	PASS
1027636	IEC LEAD	02/11/23	KYLE	P	P	P 0.13	P 19.99	PASS
1027637	IEC LEAD	02/11/23	KYLE	P	P	P 0.14	P 19.99	PASS
1027638	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027639	IEC LEAD	02/11/23	KYLE	P	P	P 0.15	P 19.99	PASS

Total Appliances > **32**

ABC COMPANY - OFFICE TEN

1027403	LAMP	01/11/23	KYLE	P	S	S	P 19.99	PASS
1027404	IEC LEAD	01/11/23	KYLE	P	P	P 0.19	P 19.99	PASS
1027405	LAPTOP CHARGER	01/11/23	KYLE	P	S	S	S	PASS
1027406	AC ADAPTER BATTERY CHARGER	01/11/23	KYLE	P	S	S	S	PASS
1027407	USB PLUG	01/11/23	KYLE	P	S	S	S	PASS
1027408	USB PLUG	01/11/23	KYLE	P	S	S	S	PASS
1027409	SMART BOARD	01/11/23	KYLE	P	S	P 0.16	P 19.99	PASS
1027410	HYDRAULIC STAND	01/11/23	KYLE	P	S	P 0.14	P 19.99	PASS
1027411	IEC LEAD	01/11/23	KYLE	P	P	P 0.13	P 19.99	PASS

Total Appliances > **9**

ABC COMPANY - OFFICE THREE

1027646	MONITOR	02/11/23	KYLE	P	S	P 0.08	P 19.99	PASS
1027647	MONITOR	02/11/23	KYLE	P	S	P 0.06	P 19.99	PASS
1027648	MONITOR	02/11/23	KYLE	P	S	P 0.08	P 19.99	PASS
1027649	MONITOR	02/11/23	KYLE	P	S	P 0.09	P 19.99	PASS
1027650	IEC LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027651	IEC LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027652	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027653	IEC LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027654	6 GANG EXTENSION LEAD	02/11/23	KYLE	P	P	P 0.15	P 19.99	PASS
1027655	MONITOR	02/11/23	KYLE	P	S	P 0.11	P 19.99	PASS
1027656	MONITOR	02/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
1027657	MONITOR	02/11/23	KYLE	P	S	P 0.09	P 19.99	PASS
1027658	IEC LEAD	02/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027659	IEC LEAD	02/11/23	KYLE	P	P	P 0.10	P 19.99	PASS
1027660	IEC LEAD	02/11/23	KYLE	P	P	P 0.09	P 19.99	PASS

Total Appliances > **15**

ABC COMPANY - OFFICE THREE STORE

1027641	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
---------	------------	----------	------	---	---	---	---	------

Total Appliances > **1**

ABC COMPANY - OFFICE TWO

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1027442	AC ADAPTER WATER LIGHT	01/11/23	KYLE	P	S	S	S	PASS
1027443	AC ADAPTER WATER LIGHT	01/11/23	KYLE	P	S	S	S	PASS
1027444	USB PLUG	01/11/23	KYLE	P	S	S	S	PASS
1027445	AC ADAPTER	01/11/23	KYLE	P	S	S	S	PASS
Total Appliances >								4

ABC COMPANY - PHYSIO ROOM

1028076	AC ADAPTER	02/11/23	CHELSEA	P	S	S	S	PASS
1028077	ELECTRIC BED	02/11/23	CHELSEA	P	S	S	S	PASS
1028078	ELECTRIC BED	02/11/23	CHELSEA	P	S	S	S	PASS
1028079	CHAIR LIFT	02/11/23	CHELSEA	P	S	S	S	PASS
Total Appliances >								4

ABC COMPANY - RECEPTION

1029868	MONITOR	01/11/23	JANE	P	S	P 0.05	P 19.99	PASS
1029869	MONITOR	01/11/23	JANE	P	S	P 0.05	P 19.99	PASS
1029870	MONITOR	01/11/23	JANE	P	S	P 0.05	P 19.99	PASS
1029871	MONITOR	01/11/23	JANE	P	S	P 0.05	P 19.99	PASS
1029872	PC	01/11/23	JANE	P	S	P 0.07	P 19.99	PASS
1029873	PC	01/11/23	JANE	P	S	P 0.05	P 19.99	PASS
1029874	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029875	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029876	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029877	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029878	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029879	IEC LEAD	01/11/23	JANE	P	P	P 0.03	P 19.99	PASS
1029880	FIG 8 LEAD	01/11/23	JANE	P	S	S	S	PASS
1029881	POWER SUPPLY UNIT	01/11/23	JANE	P	S	S	S	PASS
1029882	AC ADAPTER	01/11/23	JANE	P	S	S	S	PASS
1029883	FAN	01/11/23	JANE	P	S	S	P 19.99	PASS
Total Appliances >								16

ABC COMPANY - RECEPTION DESK

1027421	FAIRY LIGHTS	01/11/23	KYLE	P	S	S	S	PASS
1027422	AC ADAPTER BATTERY CHARGER	01/11/23	KYLE	P	S	S	S	PASS
1027423	IEC LEAD	01/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027424	LAPTOP CHARGER	01/11/23	KYLE	P	S	S	S	PASS
1027425	SMART BOARD	01/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
1027426	HYDRAULIC STAND	01/11/23	KYLE	P	S	P 0.11	P 19.99	PASS
1027427	IEC LEAD	01/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027428	LAMP	01/11/23	KYLE	P	S	S	P 19.99	PASS
1027429	SMART BOARD	01/11/23	KYLE	P	S	P 0.08	P 19.99	PASS
1027430	HYDRAULIC STAND	01/11/23	KYLE	P	S	P 0.10	P 19.99	PASS

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1027431	IEC LEAD	01/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027432	GLUE GUN	01/11/23	KYLE	P	S	S	P 19.99	PASS
1027433	GLUE GUN	01/11/23	KYLE	P	S	S	P 19.99	PASS
1027434	FAIRY LIGHTS	01/11/23	KYLE	P	S	S	S	PASS
1027435	AC ADAPTER BATTERY CHARGER	01/11/23	KYLE	P	S	S	S	PASS
1027436	IEC LEAD	01/11/23	KYLE	P	P	P 0.08	P 19.99	PASS
1027437	LAPTOP CHARGER	01/11/23	KYLE	P	S	S	S	PASS
1027438	SMART BOARD	01/11/23	KYLE	P	S	P 0.17	P 19.99	PASS
1027439	HYDRAULIC STAND	01/11/23	KYLE	P	S	P 0.10	P 19.99	PASS
1027440	IEC LEAD	01/11/23	KYLE	P	P	P 0.11	P 19.99	PASS
1027441	LAMP	01/11/23	KYLE	P	S	S	P 19.99	PASS
Total Appliances >								21

ABC COMPANY - SERVER ROOM

1027738	IEC LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027739	IEC LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027740	IEC LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027741	IEC LEAD	02/11/23	KYLE	P	S	S	S	PASS
1027742	NETWORK SWITCH	02/11/23	KYLE	P	S	S	S	PASS
1027743	NETWORK SWITCH	02/11/23	KYLE	P	S	S	S	PASS
1027744	12 GANG EXTENSION LEAD	02/11/23	KYLE	P	S	S	S	PASS
Total Appliances >								7

ABC COMPANY - STAFF ROOM

1028880	MICROWAVE OVEN	01/11/23	ROB	P	S	P 0.06	P 19.99	PASS
1028881	MICROWAVE OVEN	01/11/23	ROB	P	S	P 0.02	P 19.99	PASS
1028882	FRIDGE	01/11/23	ROB	P	S	P 0.07	P 19.99	PASS
1028883	TOASTER	01/11/23	ROB	P	S	P 0.17	P 19.99	PASS
1028884	MICROWAVE OVEN	01/11/23	ROB	P	S	P 0.02	P 19.99	PASS
1028885	FRIDGE	01/11/23	ROB	P	S	P 0.08	P 19.99	PASS
1028886	DISHWASHER	01/11/23	ROB	P	S	P 0.41	S	PASS
1028887	DISHWASHER	01/11/23	ROB	P	S	P 0.17	S	PASS
1028888	TELEVISION	01/11/23	ROB	P	S	S	S	PASS
1028889	PC	01/11/23	ROB	P	S	P 0.18	P 19.99	PASS
1028890	IEC LEAD	01/11/23	ROB	P	P	P 0.15	P 19.99	PASS
1028891	PC	01/11/23	ROB	P	S	P 0.12	P 19.99	PASS
1028892	IEC LEAD	01/11/23	ROB	P	P	P 0.12	P 19.99	PASS
1028893	AC ADAPTER	01/11/23	ROB	P	S	S	S	PASS
1028894	COFFEE MACHINE	01/11/23	ROB	P	S	S	S	PASS
1028895	USB PLUG	01/11/23	ROB	P	S	S	S	PASS
Total Appliances >								16

ABC COMPANY - STORES

APPLIANCE DETAILS AND TEST RESULTS

Key
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Engineer	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Overall Status
1027661	SANDING TOOL	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027662	BATTERY CHARGER	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027663	GRINDER	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027664	HEAT GUN	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027665	DRILL 110V 16AMP	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027666	BATTERY CHARGER	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027667	ROUTER TOOL	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027668	ROUTER TOOL	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027669	GLUE GUN	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027670	STAPLE GUN	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027671	CIRCULAR SAW	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027672	CIRCULAR SAW	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027673	SOLDERING SET	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027674	SANDING TOOL	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027675	HAMMER DRILL	02/11/23	KYLE	P	S	S	P 19.99	PASS
1027676	AIR COMPRESSOR	02/11/23	KYLE	P	S	P 0.17	P 19.99	PASS
1027677	AIR COMPRESSOR	02/11/23	KYLE	P	S	P 0.20	P 19.99	PASS
1027678	TRANSFORMER	02/11/23	KYLE	P	S	P 0.15	P 19.99	PASS
1027679	AC ADAPTER RADIO	02/11/23	KYLE	P	S	S	S	PASS
1027680	AC ADAPTER	02/11/23	KYLE	P	S	S	S	PASS
1027681	4 GANG EXTENSION REEL 15M	02/11/23	KYLE	P	P	P 0.34	P 19.99	PASS

Total Appliances > **21**

Total Appliances For Report: 641

PAT Report Notes

For all Sites and Locations

CLIENT DETAILS

Company Name: ABC Company Ltd

Address: 1 Smith Street
Simpson Trade Estate
Big Town
A12 3BC



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING

Company Name: DRA PAT Testing Ltd

Address: 27 Coquet Gardens
Wallsend
Tyne and Wear
NE28 6AG

Telephone: 01916661009

Mobile: 07897240878


Email: info@draelectricals.co.uk

Web: draelectricals.co.uk

Cert Number: RA-004920

Order Number: 366545

File Name: ABC 111.PAT

Signature: 

Electrical Equipment Certificate Report

PAT TESTER DETAILS

Serial Number	Make and Model	Certificate Number	Calibration Due Date
44G-0452	Seaward - Apollo 600	btm11770	12/09/2024
20E-0267	Seaward - Apollo 600	btm11771	21/09/2024
22J-0865	Seaward - Apollo 600	btm11432	19/07/2024
22K-0038	Seaward - Apollo 600	btm11431	19/07/2024

NOTES / ADVISORIES

Appliance Id	Appliance Description	Test Date	Status
1027640 ABC COMPANY - OFFICE THREE STORE	VACUUM CLEANER	02/11/23	FAIL
REMOVE FROM USE			
1027682 ABC COMPANY - STORES	4 GANG EXTENSION REEL 30M	02/11/23	FAIL
REMOVE FROM USE			
1027703 ABC COMPANY - BOILER HOUSE	ANGLE GRINDER	02/11/23	FAIL
REMOVE FROM USE			
1027705 ABC COMPANY - BOILER HOUSE	EXTENSION LEAD	02/11/23	PASS
RAN AROUND ROOM			
1028879 ABC COMPANY - ASSISTANT MANAGER	FAN HEATER	01/11/23	FAIL
REMOVE FROM USE			

NOTES / ADVISORIES

Appliance Id	Appliance Description	Test Date	Status
1029911 ABC COMPANY - OFFICE ONE SOCKET TESTED	2 GANG EXTENSION LEAD	01/11/23	PASS

COP 4th Edition Form V5

For all Sites and Locations



CLIENT DETAILS	
Company Name:	ABC Company Ltd
Address:	1 Smith Street Simpson Trade Estate Big Town A12 3BC

DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING	
Company Name:	DRA PAT Testing Ltd
Address:	27 Coquet Gardens Wallsend Tyne and Wear NE28 6AG
Telephone:	01916661009
Mobile:	07897240878
Email:	info@draelectricals.co.uk
Web:	draelectricals.co.uk
Cert Number:	RA-004920
Order Number:	366545
File Name:	ABC 111.PAT
Signature:	

Electrical Equipment Certificate Report

PAT TESTER DETAILS			
Serial Number	Make and Model	Certificate Number	Calibration Due Date
44G-0452	Seaward - Apollo 600	btm11770	12/09/2024
20E-0267	Seaward - Apollo 600	btm11771	21/09/2024
22J-0865	Seaward - Apollo 600	btm11432	19/07/2024
22K-0038	Seaward - Apollo 600	btm11431	19/07/2024

APPLIANCE DETAILS AND STATUS				
Appliance Id	Appliance Description	Frequency of (Months)		Status
		Formal Visual Inspection	Combined Inspection and Test	
1027640	VACUUM CLEANER	12	12	FAIL
ABC COMPANY - OFFICE THREE STORE		02/11/23	02/11/23	
FAIL REASON	VISUAL NOTES	NOTES		
CABLE IS DAMAGED		REMOVE FROM USE		
1027682	4 GANG EXTENSION REEL 30M	12	12	FAIL
ABC COMPANY - STORES		02/11/23	02/11/23	
FAIL REASON	VISUAL NOTES	NOTES		
BURNT SOCKET		REMOVE FROM USE		
1027703	ANGLE GRINDER	12	12	FAIL
ABC COMPANY - BOILER HOUSE		02/11/23	02/11/23	
FAIL REASON	VISUAL NOTES	NOTES		
CABLE IS DAMAGED		REMOVE FROM USE		

APPLIANCE DETAILS AND STATUS				
Appliance Id	Appliance Description	Frequency of (Months)		Status
		Formal Visual Inspection	Combined Inspection and Test	
1028879	FAN HEATER	12	12	FAIL
ABC COMPANY - ASSISTANT MANAGER		01/11/23	01/11/23	
FAIL REASON	VISUAL NOTES	NOTES		
MISSING SWITCH		REMOVE FROM USE		

Guidance Notes

Electrical Equipment Certificate Report Guidance Notes

You should keep this document in a safe place; it helps you to comply with the Electricity at Work Regulations (1989) among others and shows that you are operating within the expectations of British Standards to ensure your electrical equipment is safe to use.

We have inspected and (where necessary) tested your electrical equipment to make sure it is safe; and confirmed it to be so - any appliances not considered safety to continue using are noted on the Failures Report.

Any necessary repairs have been carried out, and the appliances on the "Passes" report have been deemed safe to continue using. Pay attention to any guidance notes.

Any appliances logged on the "fails" report should be removed from service and either repaired or disposed of - if you repair them, they must be retested before going back into service.

Any appliances 'fixed' to the mains via a fused spur unit; where the plug has been removed and the cable hard wired, have been visually inspected and if reliant on earth protection have been tested for earth continuity. These will need a formal test every 5 years from installation by your electrician in-line with the EICR or we can do this at a time when the power can be turned off - additional costs apply.

A repeat of this PAT inspection should be carried out as often as is necessary to ensure equipment stays safe; we recommend a maximum interval period of 12 months (all more often for high risk equipment) - we will create a diary entry to carry out retests after an appropriate amount of time and remind you when the renewal date is approaching however it is your responsibility to ensure equipment maintains safe standards at all times.

A risk assessment is recommended.

The HSE recommends equipment users carry out their own inspections of an appliance before use and report any defects to you. Defective equipment must not be used.

As well as appliance safety you need to ensure your mains wiring is safe, by having an "EICR" carried out every 3-5 years - if you have not had an electrical inspection in the past 3-5 years contact us to arrange this.

This report has been compiled DRA PAT Testing Limited.

For all queries email info@draelectricals.co.uk or call the office on 0191 666 1009.

Inspection and Testing of Electrical Equipment and installations.