



Portable Appliance Testing Report

ABC Company Ltd

Test Period Commencing

17-Mar-2021

Order No

3665

Company Contact Name

Alan Hall

Certificate of Electrical Appliance Testing

Client Details

ABC Company Ltd
1 Smith Street
Simpson Trade Estate
Big Town
A12 3BC


Certification

This company has had their portable electrical equipment inspected and tested inline with guidance from the IET's Code of Practice 5th Edition, the HSE and the Portable Appliance Testing Trade Association.

Date Tested:

17/03/2021

Signature



Certificate Number RA-004056

Carried out by

DRA PAT Testing Limited
27 Coquet Gardens
Wallsend
Tyne and Wear
NE28 6AG
Phone: 01916661009
Email: info@draelectricals.co.uk
Web: draelectricals.co.uk



CLIENT DETAILS
Company Name: ABC Company Ltd

Address: 1 Smith Street
Simpson Trade Estate
Big Town
A12 3BC

DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING
Company Name: DRA PAT Testing Limited

Address: 27 Coquet Gardens
Wallsend
Tyne and Wear
NE28 6AG

Telephone: 01916661009

Mobile:
Email: info@draelectricals.co.uk

Web: draelectricals.co.uk

Cert Number: RA-004056

Signature:
Order Number: 3665

File Name: ABC Company.PAT

PAT Testing Certificate Report
PAT TESTER DETAILS

Serial Number	Make and Model	Certificate Number	Calibration Due Date
22K-0038	Seaward - Apollo 600	sea11349	28/08/2021

APPLIANCE DETAILS AND STATUS

Appliance Id	Appliance Description	Test Date	Retest Date	Retest Period (Months)	Engineer Name	Status
ABC COMPANY - DIRECTORS						
554628	FIG 8 LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554629	LAPTOP CHARGER	17/03/21	17/03/23	24	RICHARD	PASS
554630	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554631	AC ADAPTOR	17/03/21	17/03/23	24	RICHARD	PASS
554632	6 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554633	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554634	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554635	LAPTOP CHARGER	17/03/21	17/03/23	24	RICHARD	PASS
554636	LAPTOP CHARGER	17/03/21	17/03/23	24	RICHARD	PASS
554637	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554638	AC ADAPTOR	17/03/21	17/03/23	24	RICHARD	PASS
554639	AC ADAPTOR	17/03/21	17/03/23	24	RICHARD	PASS
554645	PC	17/03/21	17/03/23	24	RICHARD	PASS
554646	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554647	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554648	LAPTOP CHARGER	17/03/21	17/03/23	24	RICHARD	PASS
554649	AC ADAPTOR	17/03/21	17/03/23	24	RICHARD	PASS
554650	AC ADAPTOR	17/03/21	17/03/23	24	RICHARD	PASS

APPLIANCE DETAILS AND STATUS

Appliance Id	Appliance Description	Test Date	Retest Date	Retest Period (Months)	Engineer Name	Status
554651	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554652	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554653	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554654	CALCULATOR	17/03/21	17/03/23	24	RICHARD	PASS
554655	AC ADAPTOR ROUTER	17/03/21	17/03/23	24	RICHARD	PASS
554656	AC ADAPTOR USB PLUG	17/03/21	17/03/23	24	RICHARD	PASS

 Total Appliances > **24**
ABC COMPANY - KITCHEN

554624	FRIDGE	17/03/21	17/03/23	24	RICHARD	PASS
554625	MICROWAVE OVEN	17/03/21	17/03/23	24	RICHARD	PASS
554626	KETTLE	17/03/21	17/03/23	24	RICHARD	PASS
554627	COFFEE MACHINE	17/03/21	17/03/23	24	RICHARD	PASS

 Total Appliances > **4**
ABC COMPANY - MAIN OFFICE

554529	PC	17/03/21	17/03/23	24	RICHARD	PASS
554530	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554531	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554532	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554533	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554534	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554535	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554536	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554537	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554538	PC	17/03/21	17/03/23	24	RICHARD	PASS
554539	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554540	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554541	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554542	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554543	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554544	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554545	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554546	PRINTER	17/03/21	17/03/23	24	RICHARD	PASS
554547	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554548	AC ADAPTOR	17/03/21	17/03/23	24	RICHARD	PASS
554549	HEATER WALL MOUNTED	17/03/21	17/03/23	24	RICHARD	PASS
554550	HEATER WALL MOUNTED	17/03/21	17/03/23	24	RICHARD	PASS
554551	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554552	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554553	PC	17/03/21	17/03/23	24	RICHARD	PASS
554554	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554555	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554556	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554557	OIL FILLED RADIATOR	17/03/21	17/03/23	24	RICHARD	PASS
554558	6 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS

APPLIANCE DETAILS AND STATUS

Appliance Id	Appliance Description	Test Date	Retest Date	Retest Period (Months)	Engineer Name	Status
554559	AC ADAPTOR	17/03/21	17/03/23	24	RICHARD	PASS
554560	AC ADAPTOR	17/03/21	17/03/23	24	RICHARD	PASS
554561	AC ADAPTOR	17/03/21	17/03/23	24	RICHARD	PASS
554562	FIG 8 LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554563	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554564	LAPTOP CHARGER	17/03/21	17/03/23	24	RICHARD	PASS
554565	FIG 8 LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554566	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554567	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554568	PHOTOCOPIER	17/03/21	17/03/23	24	RICHARD	PASS
554569	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554570	POWER SUPPLY	17/03/21	17/03/23	24	RICHARD	PASS
554571	CALCULATOR	17/03/21	17/03/23	24	RICHARD	PASS
554572	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554573	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554574	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554575	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554576	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554577	LAPTOP CHARGER	17/03/21	17/03/23	24	RICHARD	PASS
554578	CALCULATOR	17/03/21	17/03/23	24	RICHARD	PASS
554579	FIG 8 LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554580	POWER SUPPLY	17/03/21	17/03/23	24	RICHARD	PASS
554581	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554582	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554583	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554584	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554584	PC	17/03/21	17/03/23	24	RICHARD	PASS
554585	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554586	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554587	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554588	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554589	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554590	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554591	4 GANG SOCKET BLOCK	17/03/21	17/03/23	24	RICHARD	PASS
554592	OIL FILLED RADIATOR	17/03/21	17/03/23	24	RICHARD	PASS
554593	OIL FILLED RADIATOR	17/03/21	17/03/23	24	RICHARD	PASS
554594	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554595	LAPTOP CHARGER	17/03/21	17/03/23	24	RICHARD	PASS
554596	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554597	LAPTOP CHARGER	17/03/21	17/03/23	24	RICHARD	PASS
554598	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554599	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554600	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS

APPLIANCE DETAILS AND STATUS

Appliance Id	Appliance Description	Test Date	Retest Date	Retest Period (Months)	Engineer Name	Status
554601	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554602	TELEPHONE ADAPTOR	17/03/21	17/03/23	24	RICHARD	PASS
554603	FAN HEATER	17/03/21	17/03/23	24	RICHARD	PASS
554604	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554604	PC	17/03/21	17/03/23	24	RICHARD	PASS
554605	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554606	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554607	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554608	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554609	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554610	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554611	POWER SUPPLY	17/03/21	17/03/23	24	RICHARD	PASS
554612	POWER SUPPLY	17/03/21	17/03/23	24	RICHARD	PASS
554613	POWER SUPPLY	17/03/21	17/03/23	24	RICHARD	PASS
554614	POWER SUPPLY	17/03/21	17/03/23	24	RICHARD	PASS
554615	FAN HEATER	17/03/21	17/03/23	24	RICHARD	PASS
554616	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554617	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554618	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554619	MONITOR	17/03/21	17/03/23	24	RICHARD	PASS
554620	PC	17/03/21	17/03/23	24	RICHARD	PASS
554621	HEATER WALL MOUNTED	17/03/21	17/03/23	24	RICHARD	PASS
554622	WATER COOLER	17/03/21	17/03/23	24	RICHARD	PASS
554623	HEATER WALL MOUNTED	17/03/21	17/03/23	24	RICHARD	PASS

 Total Appliances > **97**
ABC COMPANY - MEETING ROOM

554640	PC	17/03/21	17/03/23	24	RICHARD	PASS
554641	IEC LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554642	FIG 8 LEAD	17/03/21	17/03/23	24	RICHARD	PASS
554643	TELEVISION	17/03/21	17/03/23	24	RICHARD	PASS
554644	HEATER WALL MOUNTED	17/03/21	17/03/23	24	RICHARD	PASS

 Total Appliances > **5**

Portable Appliance Test Reports Guidance Notes

This document serves as a reference to the inspection carried out on the listed portable electrical appliances; each has been inspected visually, and those that require it have also been tested using the PAT machine.

All electrical appliances need regular inspection and testing to make sure they are safe, including portable appliances (fitted with a plug) and fixed (hard wired) appliances as well as battery operated equipment.

This report relates only to portable equipment unless otherwise specified.

Each appliance recorded has been thoroughly visually inspected to make sure it is in the condition expected of a safe appliance; and appliances that require it have been tested.

Only appliances with exposed conductive parts or reliant on earth protection require additional electrical tests. On subsequent tests some appliances (e.g. power leads) may be tested attached to their main unit.

Tests carried out check measurements are within required parameters to maintain safe use; there is no requirement to record or provide electrical test readings.

Each appliance that needs electrical tests has been tested in accordance with IET and HSE guidance, and will be retested in line with said guidance appropriate to the risk, or client instructions, or on a 12-monthly basis - a recommended retest date is shown on the report for each appliance, defaulting to 12 months if we have not been advised otherwise by the client.

Remedial repairs are carried out automatically such as to the existing plug and or cable, or through the supply and fit of new fuses and plugs; an appliance marked safe has passed all required inspections and tests and is deemed safe to continue using.

An appliance recorded as a fail on this report, must pass a further test before going back in to service.

PAT testing will help you maintain safety standards, but users also need to check appliances before use, and if deemed dangerous or other, removed from service until which time they can be repaired.

Portable appliances have a plug, or are intended to have a plug - if the plug has been removed and the cable hard-wired via a fused spur, the appliance will have been inspected and tested for earth continuity only.

Fixed appliances require a full test every 5 years from install, usually when the EICR is completed as power needs isolating to do the test. You are responsible for ensuring this happens.

Microwave Ovens should be additionally inspected for emissions leakage, power and temperature rise every 2 years.

In order to help maintain safe electrical systems you should ensure your mains wiring inspection (EICR) is also up to date.

Inspection and testing has been carried out by employed engineers or sub-contractors of DRA PAT Testing Ltd

DRA PAT Testing provides electrical safety testing services including Portable Appliance Testing, Fixed Appliance Testing & Electrical Installation Certificate Reports.

www.draelectricals.co.uk info@draelectricals.co.uk 01916661009